PHYSICAL PROPERTIES OF KAOLIN/SAND SLURRY USED DURING SUBMERSIBLE MIXER PUMP TESTS AT TNX

Author: Erich Hansen

Vickie Williams

August 2004



This document was prepared in conjunction with work accomplished under Contract No. DE-AC09-96SR18500 with the U. S. Department of Energy.

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

This report has been reproduced directly from the best available copy.

Available for sale to the public, in paper, from: U.S. Department of Commerce, National Technical Information Service, 5285 Port Royal Road, Springfield, VA 22161,

phone: (800) 553-6847, fax: (703) 605-6900

email: orders@ntis.fedworld.gov

online ordering: http://www.ntis.gov/help/index.asp

Available electronically at http://www.osti.gov/bridge

Available for a processing fee to U.S. Department of Energy and its contractors, in paper, from: U.S. Department of Energy, Office of Scientific and Technical Information, P.O. Box 62, Oak Ridge, TN 37831-0062,

phone: (865)576-8401, fax: (865)576-5728

email: reports@adonis.osti.gov

WSRC-TR-2004-00401 Revision 0

Key Words: Kaolin, physical properties

Retention: Permanent

PHYSICAL PROPERTIES OF KAOLIN/SAND SLURRY USED DURING SUBMERSIBLE MIXER PUMP TESTS AT TNX

Author: Erich Hansen

Vickie Williams

August 2004

Immobilization Technology Section Savannah River National Laboratory Aiken, SC 29808



This page was intentionally left blank

EXECUTIVE SUMMARY

The purpose of this task is to characterize the physical properties of kaolin/sand slurry used to test the performance of a new submersible mixer pump (SMP) which is undergoing performance testing at the TNT Waste Tank mockup facility. Three different sample locations, the SMP cooling water exit (CWE), the SMP fluid flow field (FFF), and SMP effective cleaning radius (ECR) were used for sampling over the seven day test. The physical properties determinations for the kaolin/sand slurry samples include rheology, weight percent total solids (wt% TS), density, and particle size distribution (PSD) were requested, though not all these determinations were performed on all the samples.

The physical properties determinations are described in more detail in section 1.0. Measurements were performed at Savannah River National Laboratory (SRNL) in accordance with the Technical Assistance Request (TAR)¹.

The data, average of two measurements, is shown in the table below. This data clearly shows that the SMP-CWE samples contained more solids than those at other sample locations for a given sample day. The SMP-FFF and SMP-ECR were similar in solids content. The rheology of the samples is dependent on the wt% solids concentration and are all within the bounds stated in the TAR. The particle size distribution is discussed in section 1.4.

0 1	Ъ		Average of Two	Measurement	ts
Sample location	Day Pulled	wt% T.S.	Density (g/mL)	Yield stress (dynes/cm ²)	Consistency (cP)
	1	25.17	1.180	122.0	8.04
	2	24.04	1.171	107.9	7.52
	3	23.86	1.171	107.6	7.43
SMP-CWE	4	23.89	1.173	109.2	7.42
	5	23.01	1.165	95.6	6.86
	6	23.02	1.164	99.0	7.03
	7	23.23	1.167	97.9	7.03
	1	24.32	1.177	N/M	N/M
	2	23.72	1.167	N/M	N/M
	3	23.49	1.165	N/M	N/M
SMP-FFF	4	23.41	1.169	N/M	N/M
	5	22.77	1.162	N/M	N/M
	6	22.69	1.161	N/M	N/M
	7	22.92	1.164	N/M	N/M
	3	23.51	1.168	104.3	7.21
SMP-ECR	6	22.06	1.157	83.3	6.39
	7	22.97	1.165	96.7	6.98

N/M = not measured

_

¹ Altman, D., "Testing and Sampling support at TNX for Submersible Mixer Pump (SPM) Test", HAL-TAR-2004-077, Rev. 1, July 21, 2004

WSRC-TR-2004-00401 Revision 0

TABLE OF CONTENTS

EXECUTIVE SUMMARY	iii
LIST OF FIGURES	V
LIST OF TABLES	vi
LIST OF ACRONYMS	vii
1.0 INTRODUCTION AND BACKGROUND	1
1.1 Weight Percent Total Solids	2
1.2 Density	3
1.3 Rheology	4
1.4 Particle Size Distribution	8
2.0 Reference	11
APPENDIX A. 1 st Sample down flow curves fitted to bingham plastic model	12
APPENDIX B. Particle size distributuion	18
APPENDIX C: Kaolin Vendor B-100 Specifications	33

iv

LIST OF FIGURES

Figure 1-1: Typical Kaolin/Sand Flow Curve of an SMP Sample	6
Figure 1-2: Density Versus Wt% TS For SMP	7
Figure 1-3: Bingham Plastic Yield Stress Versus Wt% TS For SMP	8
Figure 1-4: Bingham Plastic Consistency Versus Wt% TS For SMP	
Figure A - 1: Down Flow Curve Sample SMP-CWE-1, Run 1	13
Figure A - 2: Down Flow Curve Sample SMP-CWE-2, Run 1	
Figure A - 3: Down Flow Curve Sample SMP-CWE-3, Run 1	
Figure A - 4: Down Flow Curve Sample SMP-CWE-4, Run 1	
Figure A - 5: Down Flow Curve Sample SMP-CWE-5, Run 1	
Figure A - 6: Down Flow Curve Sample SMP-CWE-6, Run 1	
Figure A - 7: Down Flow Curve Sample SMP-CWE-7, Run 1	
Figure A - 8: Down Flow Curve Sample SMP-ECR-3, Run 1	
Figure A - 9: Down Flow Curve Sample SMP-CWE-6, Run 1	
Figure A - 10: Down Flow Curve Sample SMP-CWE-3, Run 1	
Figure B - 1: SMP-ECR-3 Volume Distribution	19
Figure B - 2: SMP-ECR-3 Number Distribution	
Figure B - 3: SMP-FFF-4 Volume Distribution	
Figure B - 4: SMP-FFF-4 Number Distribution	
Figure B - 5: SMP-CWE-4 Volume Distribution	
Figure B - 6: SMP-CWE-4 Number Distribution	
Figure B - 7: SMP-ECR-6 Volume Distribution	
Figure B - 8: SMP-ECR-6 Number Distribution	
Figure B - 9: SMP-ECR-7 Volume Distribution	
Figure B - 10: SMP-ECR-7 Number Distribution	
Figure B - 11: SMP-FFF-7 Volume Distribution	
Figure B - 12: SMP-FFF-7 Number Distribution	
Figure B - 13: SMP-CWE-7 Volume Distribution	
Figure B - 14: SMP-CWE-7 Number Distribution	

V

LIST OF TABLES

Table 1-1: Analysis Requested of Provided Samples	1
Table 1-2: Sample Location and Method of Sampling for the SMP Test	1
Table 1-3: Kaolin/Sand Weight Percent Total Solids Data for the SMP	3
Table 1-4: Kaolin/Sand Density Data for the SMP	4
Table 1-5: RS600 Measuring Head Specifications	4
Table 1-6: Z41 Rotor Specifications and Ramp Rates	5
Table 1-7: Cole-Parmer NIST Traceable Newtonian Oil Standard	5
Table 1-8: Kaolin/Sand Bingham Plastic Rheological Data for the SMP	7
Table 1-9: Unimin B-100 Kaolin PSD – Percent Weight on Oxide Basis	9
Table 1-10: ASTM Specification for Aggregate (Sand) Used in SMP Test	9
Table 1-11: PSD of Aggregate (Sand) Provided to SRNL	10
Table 1-12: Mean Volume and Number Particle Size Diameters for SMP Samples	11

vi

LIST OF ACRONYMS

ACTL Aiken County Technology Laboratories
ADS Analytical Developmental Section

CWE Cooling Water Exit

DI De-ionized

ECR Effective Cleaning Radius

FFF Fluid Flow Field

ITS Immobilization Technology Section

NIST National Institute of Standards and Technology

N/M Not Measured

PSD Particle Size Distribution SMP Submersible Mixer Pump

SRNL Savannah River National Laboratory

TAR Technical Assistance Request

WOW Waste on Wheels

wt% TS Weight Percent Total Solids

vii

1.0 INTRODUCTION AND BACKGROUND

Waste on Wheels (WOW) engineering requested SRNL Immobilization Technology Section (ITS) to perform physical characterization of the kaolin/sand slurry used to characterize the performance of a new SMP. The testing of the new SMP was performed at the TNX Waste Tank mockup facility. During the 7² day SMP test using the kaolin/sand slurry, samples were pulled from three different locations. The sampling day, sample location, and requested physical property analyses are shown in Table 1-1.

Day sample Day 1 Day 2 Day 3 Day 4 Day 5 Day 6 Day 7 pulled SMP-CWE SMP-CWE SMP-CWE SMP-CWE SMP-CWE SMP-FFF SMP-ECR SMP-ECR SMP-ECR SMP-FFF SMP-ECR SMP-ECR SMP-FFF SMP-FFF Sample Location Rheology X X X X X Analysis X X X X X X Density X X X X wt% TS X X X X PSD

Table 1-1: Analysis Requested of Provided Samples

Blanks mean specified analysis was not requested for this sample.

The location and method of sampling is provided in Table 1-2. A 400 mL sample at each sample location per day was required to complete the necessary physical characterization.

Table 1-2: Sample Location and Method of Sampling for the SMP Test

Location	Sampling Method
SMP - Cooling Water Exit (CWE)	There are four discharge motor cooling streams leaving the motor housing. A clean stainless steel beaker will be used to gather a sample from the discharge and sample(s) poured into a sample bottle. The sample cup was wetted with the CWE prior to sampling.
SMP - Fluid Flow Field (FFF)	A pump was used to pull a sample from the discharge of the rotating SMP. The sample was pulled two feet from the bottom of the tank when the jet rotated into the sampling location.
SMP – Effective Cleaning Radius (ECR)	A dip sample (1 to 3 feet deep) was collected from a stagnant zone near the edge of the tank opposite of the SMP.

Once the samples were received at SRNL, samples that required PSD analysis were pulled and delivered to the Analytical Development Section (ADS) for analysis. Prior to pulling the sample, the sample bottles were homogenized. The remaining analyses occurred at Aiken County

² Kaolin/Sand slurry samples from the SMP testing were sampled from July 15th through July 21st, 2004.

Technology Laboratories (ACTL). The following sections describe the method used to perform the various analyses, the results, and any conclusions.

Prior to any measurement at ACTL, the samples were homogenized. Additional handling of the sample was performed prior to rheological measurements and is described in more detail in the rheology section.

1.1 Weight Percent Total Solids

Weight percent total solids were performed using a Mettler Toledo HR83 Halogen Moisture analyzer. This moisture analyzer uses a load cell that continuously measures the mass of the sample during the measurement and a halogen heat lamp that is controlled by an infrared thermometer. The mass of a sample pan is first measured and the weight tared. Approximately a 1.5 to 3 gram sub-sample of the kaolin/sand sample is placed onto the sample pan and this mass is recorded by the analyzer. The temperature of the sample is then ramped to 105°C and maintained at 105°C throughout the measurement. The temperature is maintained until the weight of the sample does not change more than 1 milligram over a 20 second period and this final mass is recorded by the analyzer. The wt% TS is then determined by taking the ratio of the final mass to initial mass and multiplying this value by 100%. The analyzer load cell is checked on a daily basis (when used) using a 2.0 gram weight and functionally checked using a 7.0 wt% salt solution.

For each sample that required wt% TS, two replicates were analyzed. The individual results, average and percent standard deviation are shown in Table 1-3. There were no limits provided in the TAR stating the range in which the wt% TS must be within. The SMP procurement specification³ states wt% solids range of 0 to 17% (section 3.3.1.1) for tank environmental conditions and a 20 wt% TS (section 4.1.3) for SMP acceptance testing. In both case, the wt% TS of the kaolin/sand slurries exceeded these limits. The data does reveal that samples pulled on the same day, the CWE samples are slightly higher in wt% TS as compared to the FFF and ECR samples. The FFF and ECR samples pulled on the same days have similar wt% TS results.

-

³ M-SPP-G-00302, "Procurement Specification – Submersible Mixer Pump", Rev. 1, May 23, 2003

Table 1-3: Kaolin/Sand Weight Percent Total Solids Data for the SMP

	Day	1	Weight Perce	nt Total So	lids
Sample location	Pulled	Sample 1	Sample 2	Average	% standard deviation
	1	25.25	25.08	25.17	0.48%
	2	24.03	24.04	24.04	0.03%
	3	23.80	23.91	23.86	0.33%
SMP-CWE	4	23.84	23.94	23.89	0.30%
	5	22.93	23.08	23.01	0.46%
	6	22.90	23.13	23.02	0.71%
	7	23.29	23.17	23.23	0.37%
	1	24.22	24.42	24.32	0.58%
	2	23.84	23.60	23.72	0.72%
	3	23.48	23.49	23.49	0.03%
SMP-FFF	4	23.44	23.38	23.41	0.18%
	5	22.71	22.82	22.77	0.34%
	6	22.81	22.56	22.69	0.78%
	7	22.90	22.94	22.92	0.12%
	3	23.58	23.44	23.51	0.42%
SMP-ECR	6	22.13	21.99	22.06	0.45%
	7	22.93	23.01	22.97	0.25%

1.2 Density

Densities were performed using an Anton Paar DMA 4500 Density analyzer. A sample is pushed in to the density analyzer u-tube, the sample temperature corrected to 25°C, a vibration is induced on one end of the u-tube and the frequency is measured at the other end. The density of the sample is determined on the measured frequency. The density analyzer is functionally checked on a daily basis (when used) with DI water.

For each sample that required density, two replicates were analyzed. The individual results, average and percent standard deviation are shown in Table 1-4. Specific gravity testing limits provided in the SMP procurement specification ranged from 1.0 to 1.5 (section 3.3.1.1)³ for the supernatant but also specified testing the SMP using a kaolin slurry with a specific gravity of 1.14 (page 14)⁴ for acceptance testing. The density of the kaolin/sand slurry samples were above the specific gravity for acceptance testing. The data reveals that samples pulled on the same day the CWE samples have a higher density as compared to the FFF and ECR samples and this is supported by the wt% TS data. The FFF and ECR samples pulled on the same day have similar density results.

-

⁴ M-DCF-F-03629

Table 1-4: Kaolin/Sand Density Data for the SMP

	Day		Density	y (g/mL)	
Sample location	Pulled	Sample 1	Sample 2	Average	% standard deviation
	1	1.180	1.180	1.180	0.02%
	2	1.171	1.171	1.171	0.01%
	3	1.171	1.171	1.171	0.00%
SMP-CWE	4	1.173	1.173	1.173	0.00%
	5	1.165	1.165	1.165	0.00%
	6	1.164	1.164	1.164	0.00%
	7	1.167	1.167	1.167	0.01%
	1	1.177	1.177	1.177	0.00%
	2	1.167	1.167	1.167	0.00%
	3	1.165	1.165	1.165	0.00%
SMP-FFF	4	1.169	1.169	1.169	0.00%
	5	1.162	1.162	1.162	0.01%
	6	1.161	1.161	1.161	0.01%
	7	1.164	1.164	1.164	0.00%
	3	1.168	1.168	1.168	0.01%
SMP-ECR	6	1.157	1.157	1.157	0.01%
	7	1.165	1.165	1.165	0.00%

1.3 Rheology

The Haake RS 600 rheometer was used for all rheological measurements performed in this task. Published RS600 specifications are shown in Table 1-5. The samples for rheological measurements were shaken for at least 1 minute prior to the initial measurement and the sample was shaken for at least 30 seconds prior to the second measurement.

Table 1-5: RS600 Measuring Head Specifications

Specification	Units	Value
Maximum Torque	N-m	0.5 x 10 ⁻⁷
Minimum Torque (recommended)	N-m	0.2
Maximum Speed	RPM	1500
Minimum Speed	RPM	0.001

Flow curve measurements were obtained using a concentric (Z41) cylindrical rotor. The design is shown in Table 1-6. The Z41rotor is initially installed onto the RS600 and a zero reference point is determined by the rheometer. The Z41 rotor is then removed. A homogenized sample is then placed into the appropriate cup and lowered into a temperature/controlled cup holder, which controlled the temperature at 25°C. The RS600 rheometer can control the rate at which the rotor spins and measures both the rotational speed and the torque (the resistance to shear). The shear stress at the wall of the rotating rotor is then calculated (internally by the Haake

software) based on the product of the measured torque and geometry (A-factor) of the rotor. The shear rate of the rotating rotor is calculated as the product of the measured speed and geometry (M-factor, assumes fluid is Newtonian) of the rotor. The A-factor, M-factor, shear rate range and the ramp up time, hold time at maximum shear rate, and ramp down time are provided in Table 1-6.

Design of Rotor Z41 Rotor Rotor radius (mm) $R_i = 20.7$ Cup Radius (mm) $R_a = 21.7$ Height of rotor (mm) L = 55Sample Volume (cm³) V = 15A factor (Pa/(N·m)) 6750 M factor $(s^{-1}/(rad \cdot s^{-1}))$ 22.40 Measuring Range (s⁻¹) 0 - 10005 Ramp up time (min) Hold time (min) 1 Ramp down time (min) 5

Table 1-6: Z41 Rotor Specifications and Ramp Rates

Prior to performing any flow curve measurement, the rotor and cup are inspected for visual damage that could potentially impact the flow measurement. National Institute of Standards and Technology (NIST) traceable Newtonian oil standards were used to verify the operability of the RS600 at a measurement temperature of 25°C. The viscosity of the NIST traceable Newtonian oil standards at 25°C is shown in Table 1-7. The flow curve for the NIST standard was analyzed as a Newtonian fluid and the calculated viscosity was compared to its NIST traceable Newtonian value. The rheometer is considered operable if the calculated viscosity is within \pm 10% of the NIST traceable Newtonian oil standard viscosity as stated in Table 1-7. The measured viscosity of the NIST standard was 53.0 cP, well within the required range.

Table 1-7: Cole-Parmer NIST Traceable Newtonian Oil Standard

Standard	Vis	cosity (cP) at 2	25°C	Lot Number	Expiration
Type	-10%	Reported	+10%	Lot Number	Date
N35	46.34	51.49	56.64	130704	2/6/2006

For each sample that required rheology, two replicates were analyzed. A typical flow curve is shown in Figure 1-1. Inspection of this flow curve shows that the down curves were better defined at the lower shear rates and were slightly more viscous than the up curve, hence the down curves were selected as the curve to be analyzed for all samples. There is however, very little difference between the up and down curves.




Figure 1-1: Typical Kaolin/Sand Flow Curve of an SMP Sample

The down curves were analyzed as a Bingham Plastic fluid (equation 1-1) and the 1st measurements are fitted with the Bingham Plastic curves and are shown in Appendix A. All the flow curves were fitted with the Bingham Plastic model between a shear rate of 100 sec⁻¹ to 1000 sec⁻¹. The down curve results for the Bingham Plastic yield stress and consistency include the individual measurements, average and percent standard deviation, and are summarized in Table 1-8. Limits provided in the TAR as well as in the procurement specification³ for the Bingham Plastic parameters were 10 to 300 dynes/cm² for the yields stress and 3 to 50 cP for the consistency. In all cases, the kaolin/sand slurry samples Bingham Plastic yield stresses and consistencies were below 50% of the maximum yield stress and consistency values.

$$\tau = \tau_{BP} + \eta_{BP} \cdot \dot{\gamma} \tag{1-1}$$

Where: τ = shear stress (dynes/cm²) {Note 1 Pa = 10 dynes/cm²) $\dot{\gamma}$ = shear rate (sec⁻¹)

 τ_{BP} = Bingham Plastic yield stress (dynes/cm²)


 η_{BP} = Bingham Plastic Viscosity (or consistency) {centipose = cP}

Table 1-8: Kaolin/Sand Bingham Plastic Rheological Data for the SMP

Sample	Day		Yield Stress (dynes/cm ²)			Consistency (cP)			
location	Pulled	Sample 1	Sample 2	Average	% standard deviation	Sample 1	Sample 2	Average	% standard deviation
	1	122.4	121.7	122.0	0.38%	8.09	7.98	8.04	0.95%
	2	108.6	107.1	107.9	0.97%	7.58	7.46	7.52	1.07%
	3	108.7	106.6	107.6	1.37%	7.47	7.38	7.43	0.80%
SMP-CWE	4	108.6	109.8	109.2	0.73%	7.39	7.45	7.42	0.52%
	5	95.4	95.9	95.6	0.39%	6.85	6.87	6.86	0.28%
	6	99.0	99.0	99.0	0.02%	7.04	7.01	7.03	0.34%
	7	98.8	96.9	97.9	1.42%	7.07	6.99	7.03	0.81%
	3	103.6	105.1	104.3	1.05%	7.11	7.31	7.21	1.96%
SMP-ECR	6	83.6	83.0	83.3	0.55%	6.41	6.38	6.39	0.32%
	7	96.1	97.3	96.7	0.87%	6.96	7.00	6.98	0.38%

This data reveals that the samples pulled on the same day from the CWE are more viscous when compared to the ECR samples. This is supported by the wt% TS and density data, were the CWE results are greater than that of the ECR results, indicating that the rheology should be more viscous for the CWE sample. The relationship between density, yield stress and consistency with that of wt% TS for the CWE and ECR samples is very linear between the wt% TS range tested here (22 to 25¼ wt% TS) and is shown in Figure 1-2, Figure 1-3, and Figure 1-4. These figures shows that SMP slurry samples pulled from the CWE and ECR locations are very similar in nature, given a wt% TS. Hence there were no additional physical analysis of the samples for wt% TS, density or rheology.

Figure 1-2: Density Versus Wt% TS For SMP







Figure 1-3: Bingham Plastic Yield Stress Versus Wt% TS For SMP

Figure 1-4: Bingham Plastic Consistency Versus Wt% TS For SMP



1.4 Particle Size Distribution

Appendix C contains selected technical data of the B-100 dry kaolin used in the SMP tests. The 2nd page of this appendix contains the particle size distribution (PSD), on an oxide mass basis, which indicates that 98 percent of the kaolin is smaller than 20 microns and 42 percent smaller than 0.5 microns. The results are summarized in Table 1-9.

Table 1-9: Unimin B-100 Kaolin PSD – Percent Weight on Oxide Basis

Bin	Size (microns)	% in Bin	% Cummulative
1	<u>≥</u> 20	2	100
2	$10 \le x < 20$	6	98
3	$5 \le x < 10$	9	92
4	$2 \le x < 5$	16	83
5	$1 \le x < 2$	11	67
6	$0.5 \le x < 1$	14	56
7	x < 0.5	42	42

The sand used during the SMP testing was an aggregate⁵ used for masonry mortar. The nominal particle size distribution provided in the ASTM specification, for either natural or manufactured sand is shown in Table 1-10.

Table 1-10: ASTM Specification for Aggregate (Sand) Used in SMP Test

Sieve Size		Percent Passing		
Sieve Size		Natural Sand	Manufactured Sand	
4.75 – mm	No. 4	100	100	
2.36 - mm	No. 8	95 to 100	95 to 100	
1.18 - mm	No. 16	70 to 100	70 to 100	
600 - μm	No. 30	40 to 75	40 to 75	
300 - μm	No. 50	10 to 35	20 to 40	
150 - μm	No. 100	2 to 15	10 to 25	
75 - μm	No. 200	0 to 5	0 to 10	

A sample of the sand that was provided to SRNL was dried and the PSD was determined using an ATM Sonic Sifter, which utilizes ASTM sieves. The sonic sifter uses both vibration and pulsing to sieve the material through the selected ASTM sieves. The sieves used and results are provided in Table 1-11. Table 1-10 and Table 1-11 clearly show that the sand particles are much larger than that of the B-100 kaolin.

9

-

⁵ ASTM C144-03, "Standard Specification For Aggregate for Masonry Mortar", 2003

Table 1-11: PSD of Aggregate (Sand) Provided to SRNL

Sieves		Sample				Average	
Sieve Size	Micron	#1	#2	#3	#4	Average	
425 μm	x ≥ 425	39.13%	33.31%	40.90%	31.16%	36.13%	
250 μm	$425 > x \ge 250$	40.00%	39.54%	39.84%	38.91%	39.57%	
180 μm	$250 > x \ge 180$	12.69%	16.31%	12.36%	15.64%	14.25%	
125 μm	$180 > x \ge 125$	6.24%	7.65%	5.50%	9.81%	7.30%	
75 μm	$125 > x \ge 75$	1.61%	2.63%	1.25%	3.65%	2.28%	
45 μm	$75 > x \ge 45$	0.20%	0.41%	0.11%	0.62%	0.33%	
Fines Collector	x < 45	0.13%	0.14%	0.04%	0.22%	0.13%	

A Microtrac S-3000 particle size analyzer was used to measure the PSD of the kaolin/sand samples. Prior to analyzing the sample, the kaolin/sand samples were diluted using DI water. The S-3000 particle size analyzer measures the particle diameters by measuring the scattered light from a laser beam projected through a stream of the fluid carrying the diluted sample. The amount and direction of the light scattered by the particles is measured by an optical detector array and then analyzed to determine the size distribution of the particles. The S-3000 measuring range is between 0.026 to 1408 um and is functional checked using NIST traceable particle size standards. The sample is run three times and the values averaged. The particle size distribution, both volume (would be mass basis if only one type of material is being tested or if the different materials all have the same density) and number are provide in Appendix D for the requested data in Table 1-1. The mean volume and number diameters are provided in Table 1-12. The mean number diameters are fairly constant, stating that there are a lot of small particles, most likely from the kaolin. There are slight variations between the mean volume diameter and this is due to a large particle being measured (large particles can easily shift this distribution). It is hard to determine if the sand used in the slurry degraded to a smaller PSD due to pumping or if the larger sand particles settled out of the slurry and are laying on the bottom of the tank. There were no specifications for particle size in either the TAR or the SMP procurement specification.

Table 1-12: Mean Volume and Number Particle Size Diameters for SMP Samples

Sample location	ample location Day Pulled		Mean Number (mm)	
	1	N/M	N/M	
	2	N/M	N/M	
	3	N/M	N/M	
SMP-CWE	4	6.709	0.651	
	5	N/M	N/M	
	6	N/M	N/M	
	7	9.475	0.626	
	1	N/M	N/M	
	2	N/M	N/M	
	3	N/M	N/M	
SMP-FFF	4	6.799	0.639	
	5	N/M	N/M	
	6	N/M	N/M	
	7	12.50	0.622	
	3	5.876	0.625	
SMP-ECR	6	14.02	0.622	
	7	6.374	0.654	

2.0 REFERENCE

WSRC-NB-2004-00122, Laboratory Notebook, "TNX Physical Properties of Kaolin"

WSRC-TR-2	2004-0040	1
	Revision	0

APPENDIX A. 1ST SAMPLE DOWN FLOW CURVES FITTED TO BINGHAM PLASTIC MODEL






Figure A - 1: Down Flow Curve Sample SMP-CWE-1, Run 1








Figure A - 3: Down Flow Curve Sample SMP-CWE-3, Run 1

Figure A - 4: Down Flow Curve Sample SMP-CWE-4, Run 1







Figure A - 5: Down Flow Curve Sample SMP-CWE-5, Run 1

Figure A - 6: Down Flow Curve Sample SMP-CWE-6, Run 1







Figure A - 7: Down Flow Curve Sample SMP-CWE-7, Run 1

Figure A - 8: Down Flow Curve Sample SMP-ECR-3, Run 1







Figure A - 9: Down Flow Curve Sample SMP-CWE-6, Run 1

Figure A - 10: Down Flow Curve Sample SMP-CWE-3, Run 1



WSRC-TR-2004-0040)]
Revision	ſ

APPENDIX B. PARTICLE SIZE DISTRIBUTUION




Figure B - 1: SMP-ECR-3 Volume Distribution




Figure B - 2: SMP-ECR-3 Number Distribution




Figure B - 3: SMP-FFF-4 Volume Distribution




Figure B - 4: SMP-FFF-4 Number Distribution




Figure B - 5: SMP-CWE-4 Volume Distribution




Figure B - 6: SMP-CWE-4 Number Distribution




Figure B - 7: SMP-ECR-6 Volume Distribution




Figure B - 8: SMP-ECR-6 Number Distribution




Figure B - 9: SMP-ECR-7 Volume Distribution




Figure B - 10: SMP-ECR-7 Number Distribution




Figure B - 11: SMP-FFF-7 Volume Distribution




Figure B - 12: SMP-FFF-7 Number Distribution




Figure B - 13: SMP-CWE-7 Volume Distribution




Figure B - 14: SMP-CWE-7 Number Distribution

WSRC-TR-20	004-00401
I	Revision (

APPENDIX C: KAOLIN VENDOR B-100 SPECIFICATIONS

TECHNICAL DATA



FEATURES AND BENEFITS

HEPHZIBAH, GA

VANTAGE™ refractory grade clays are custom blends of highly refractive kaolinite. These plastic clays can be employed as the primary component of cast bodies, but are most commonly used to enhance the performance of calcined kaolinic clays. Their excellent plasticity and dry strength improve the production rate and shape retention of the refractory, and a high PCE value helps to extend refractory service life.

VANTAGE™ finds application in a variety of intermediate to high duty firebricks, shapes, insulating bricks and saggars where good shape retention and spalling resistance is required. VANTAGE also serves as the plastic component in monolithic refractories including castable, ramming and gunning mixes and mortars. Of critical importance in these applications is a high alumina to alkali ratio to produce durable, highly refractory materials with excellent stability. VANTAGE particle size distributions will also help to minimize drying shrinkage prior to installation.

All VANTAGE™ fire clays are mined and processed under rigid QIPsm statistical quality assurance programs. The result is consistent mineralogy, chemical and physical properties, predictable results in demanding refractory applications.

CHEMICAL AND ANALYTICAL DATA Mean Values. These Do Not Represent A Specification.

		<u>B-100</u>	<u>HT100</u>	LT100	SLURRY C	<u>B-150</u>
Silicon Dioxide	(SIO ₂)	45.00	44.50	44.70	44.70	45.40
Aluminum Oxide	(Al_2O_3)	38.00	38.60	38.50	38.60	39.25
Titanium Dioxide	(TIO ₂)	1.54	1.45	1.62	1.68	1.54
Iron Oxide	(Fe ₂ O ₃)	.77	.40	.32	.34	.66
Calcium Oxide	(CaO)	.04	.04	.03	.04	.02
Magnesium Oxide	(MgO)	.08	.05	.13	.13	.14
Potassium Oxide	(K ₂ O)	.51	.28	.10	.09	.24
Sodium Oxide	(Na ₂ O)	.06	.03	.08	.08	.06
Loss on Ignition	(LOI)	13.50	13.70	13.70	14.00	13.70
			HIGH TEMP SP100	LOW TEMP SP100	Sodium Polyacrylate Dispersant	
M.B.I (meq/100g)		3.2	2.6-3.0	1.9-2.4	1.8-2.2	3.4
SSA m²/g		15.5	13.0-14.5	10.2-12.0	10.6	15.3
pH @10% Solids	2	4.5-5.5	4.5-5.5	4.5-5.5	4.8-5.8	4.5-5.5
M.O.R. (Dried @ 230°F) lbf/ln ²		200-300	100-200	100-200	100-200	100-200
% Water Absorption 1120°C		24.1	23.2	23.4	22.5	22.3
1220°C		15.5	16.3	15.4	16.4	16.1
%Linear Shrinkage Dry-Fired 1120°C		3.9	4.2	4.0	3.9	4.4
_	1220°C	5.2	5.6	5.9	4.9	6.0

TECHNICAL DATA



PARTICLE SIZE ANALYSIS AND PROPERTIES Mean Values. These Do Not Represent A Specification

Mean Percent By Weight on Oxide Basis

	MICRONS	<u>B-100</u>	HT100	LT100	SLURRY C	B-150
% Finer	<20µ	98	98	97	97	98
	<10µ	92	92	88	89	90
	<5u	83	81	76	75	77
	<2u	67	58	56	54	58
	<1µ	56	42	40	39	47
	<0.5µ	42	26	22	24	32

ORDERING INFORMATION

Shipping Point: HEPHZIBAH, GEORGIA

ORIGINATING RAIL CARRIER: NORFOLK SOUTHERN

Avallability: 50 LB. BAGS, INTERMEDIATE BULK BAGS, AND BULK

TRUCK AND RAIL



FOR PRODUCT INFORMATION AND CUSTOMER SERVICE: US and Canada 800-243-9004 Fax 800-243-9005 Worldwide 203-966-1306 Fax 203-972-1378

Silica Sanda - Ground Silica - Feldspar - Ball Clay - Kaolin - Nepheline Syenite - High Purity Quartz - Olivine - Microcrystalline Silica - Bentonite Clay - Dolomite

GRADE NUMBERS INDICATE RELATIVE VALUES OR RESULTS. THEY ARE NOT A SPECIFIATION OR WARRANTY OF PERFORMANNCE.

HEALTH HAZARD WARNING: Long term exposure can cause pneumoconiosis. This material contains crystalline silica which can cause pneumoconiosis. Pneumoconiosis is a respiratory disease, which can result in delayed, disabling and sometimes tatal lung injury. IARC has determined that crystalline silica inhaled from occupational sources can cause cencer in humans. Risk of injury is dependent on the duration and level of exposure. Avoid creating dust when handling, using or storing. Use only with adequate vantilation to keep exposure below recommended exposure limits. Follow OSHA or other relevant safety and health standards for "Particulaties ent otherwise classified" (PNOC) and for the form of crystalline silica called Quartz. Current material safety data sheet containing safety information is available and should be consulted before opening.

Notice: While information contained herein is correct to the best of our knowledge, Unimin Corporation herein discialine any warranties as to the accuracy of the same. Recommendations of suggestions are made without guarantee or representation as to result, since conditions of usage are beyond our control. All materials are sold to Unimin Corporation standards terms and conditions of sale and the conditions that buyer shall make his own tests to determine the suitability of such product for buyer's purpose. No statement contained herein shall be construed as a recommendation to intringe any palent.

Kaolin/Silica Containing Vantageres a trademark of UNIMin Corporation or its subsidiaries. All rights reserved.

Hephzibah – Vantage 68/01